

# Memorandum



**Date:** September 13, 2005

**To:** Diane O'Quinn-Williams, Director  
Department of Planning and Zoning

**From:** Jose Gonzalez, P.E., Assistant Director  
Environmental Resources Management

A handwritten signature in black ink, appearing to read "Jose Gonzalez", written over a light blue horizontal line.

**Subject:** C-14 #Z2005000188-Revised  
Three M Development, Inc.  
S/O SW 312<sup>th</sup> Street and E/O theoretical SW 190<sup>th</sup> Avenue  
District Boundary Change from AU to RU-1  
(AU) (2.5 Ac.)  
14-57-38

---

The Department of Environmental Resources Management (DERM) has reviewed the subject application and has determined that it meets the minimum requirements of Chapter 24 of the Code of Miami-Dade County, Florida (the Code). Accordingly, DERM may approve the application, and the same may be scheduled for public hearing.

Potable Water Supply:

Public water can be made available to this site; therefore, connection will be required.

Existing public water facilities and services meet the Level of Service (LOS) standards set forth in the Comprehensive Development Master Plan (CDMP). Furthermore, the proposed development order, if approved, will not result in a reduction in the LOS standards subject to compliance with the conditions required by DERM for this proposed development order.

Wastewater Disposal:

The closest public sanitary sewer main is a 24-inch force main located at the intersection of S.W. 189<sup>th</sup> Avenue and S.W. 316<sup>th</sup> Street, approximately 675 feet from the site; beyond feasible distance for connection to the public sanitary sewer system. Consequently, any proposed development would have to be served by a septic tank and drainfield as a means for the disposal of domestic liquid waste.

The subject application seeks to subdivide a parcel of land into eight lots. Section 24-13.1(3) of the Code provides that the minimum lot size for a single family residence served by public water and a septic tank shall be 15,000 square feet (gross) of unsubmerged land. Inasmuch as the proposed RU-1 zoning classification would permit lots that would have less area than what the Code requires, the applicant has applied for and obtained a variance from the requirements of the aforesaid Code Section from the Miami-Dade County Environmental Quality Control (EQCB). Accordingly, DERM may approve the applicant and the same may be scheduled for public hearing. The applicant is advised that regardless the density permitted under the requested RU-1 zoning classification, the maximum number of lots that DERM would approve for the subject property is eight, as provided for by the approval granted by the EQCB.

Stormwater Management:

A Surface Water Management General Permit from DERM shall be required for the construction and operation of the required surface water management system. This permit shall be obtained prior to site

development, final plat or public works approval of paving and drainage plans. The applicant is advised to contact DERM for further information regarding permitting procedures and requirements.

All stormwater shall be retained on site utilizing properly designed seepage or infiltration drainage structures. Drainage must be provided for the 5-year storm event with full on-site retention of the 25-year/3 day storm. Pollution Control devices shall be required at all drainage inlet structures.

Site grading and development shall comply with the requirements of Chapter 11C of the Code.

Any proposed development shall comply with County and Federal flood criteria requirements. The proposed development order, if approved, will not result in a reduction in the LOS standards for flood protection set forth in the CDMP subject to compliance with the conditions required by DERM for this proposed development order.

Wetlands:

The subject property does not contain jurisdictional wetlands as defined by Section 24-5 of the Code; therefore, a Class IV Wetland Permit will not be required.

The applicant is advised that permits from the Army Corps of Engineers (305-526-7181), the Florida Department of Environmental Protection (561-681-6600) and the South Florida Water Management District (1-800-432-2045) may be required for the proposed project. It is the applicant's responsibility to contact these agencies.

Tree Preservation:

There are no tree resources issues on this property. Therefore, no tree permits will be required.

Enforcement History:

DERM has reviewed the Permits and Enforcement database and the Enforcement Case Tracking System and has found no open or closed formal enforcement records for the subject properties identified in the subject application.

Concurrency Review Summary:

DERM has conducted a concurrency review for this application and has determined that the same meets all applicable LOS standards for an initial development order, as specified in the adopted CDMP for potable water supply, wastewater disposal and flood protection. Therefore, the application has been approved for concurrency subject to the comments and conditions contained herein.

This concurrency approval does not constitute a final concurrency statement and is valid only for this initial development order as provided for in the adopted methodology for concurrency review. Additionally, this approval does not constitute any assurance that the LOS standards would be met by any subsequent development order applications concerning the subject property.

In summary, the application meets the minimum requirements of Chapter 24 of the Code and therefore, it may be scheduled for public hearing; furthermore, this memorandum shall constitute DERM's written approval to that effect as required by the Code.

cc: Lynne Talleda, Zoning Evaluation- P&Z  
Ron Connally, Zoning Hearings- P&Z  
Franklin Gutierrez, Zoning Agenda Coordinator-P&Z